

MASTER ENGINEERS AND DESIGNERS, P.C.

2940 Fulks Street, P.O. Box 2239, Lynchburg, Virginia 24501
434/846-1350 · Fax 434/846-1351

ADDENDUM NO. 1

Date: February 25, 2004

To: ALL PLAN HOLDERS

Reference: Second Floor Renovations
College Hill Water Filter Plant
Department of Public Works
City of Lynchburg, Virginia
MEAD Project No. 262-154

THIS ADDENDUM SHALL BE ADDED TO AND BECOME A PART OF THE CONSTRUCTION DOCUMENTS AND MODIFIES THE CONSTRUCTION DOCUMENTS ONLY TO THE EXTENT OF AND IN THE PARTICULARS AS HEREINAFTER SET FORTH, BUT IN NO OTHERS.

SPECIFICATIONS

1. Section DI, Drawing Index: Delete references to Drawing C-1.
2. Section 01000 - General Requirements:
 - A. Paragraph 1.11: Owner Occupancy: Add Subparagraph K as follows:

“K. The Owner shall remove all stored material from the area of new Rooms 102 and 103. All other work shall be by the contractor and coordinated with the Owner.”

DRAWINGS

1. Cover Sheet: Delete references to Drawing C-1.
2. Drawing A-1:
 - A. Clarification: All rooms listed in Finish Schedule shall receive new ACT ceilings and grid.
 - B. Clarification: Metal studs shall be 20 ga: joists shall be 16 ga.
 - C. Clarification: Steel overhead door head and jambs at in-fill wall shall remain.
3. Drawing C-1:
 - A. Omit Drawing C-1 from the scope of the project.

END OF ADDENDUM NO. 1